

Pipe Hangers

Pipe hangers are used to support a sprinkler piping system from the building structure. Two or more listed components may be required to form a complete hanger. The specific components required depend upon the type of building construction and the pipe size.

Hilti Inc, Pipe Hangers

<i>Product Designation</i>	<i>Hanger Rod Size, mm</i>	<i>Component Description</i>	<i>For Nominal Pipe Size, in.</i>
MP-SP	10	Loop Hanger	3/4 through 4
	12	"	133 mm through 6
	16	"	219 mm
MP-MS	10	Pipe Clamp Hanger	68/72 through 4
MP-MS2	12	"	133 mm through 6
	16	"	219 mm
MF-SKD-M10	10	Toggle	3/4 through 1 1/2
MF-TSH-M10	10	Suspension Hanger	3/4 through 2
LH 3/4	3/8	Loop Hanger	3/4
LH 1	3/8	"	1
LH 1 1/4	3/8	"	1 1/4
LH 1-1/2	3/8	"	1 1/2
LH 2	3/8	"	2
LH 2 1/2	3/8	"	2 1/2
LH 3	3/8	"	3
LH 4	3/8	"	4
LH 6	1/2	"	6
LH 8	1/2	"	8
BC-WM 3/8	3/8	Beam Clamp	3/4 through 4
BC-WM 1/2	1/2	"	3/4 through 8
BC 3/8	3/8	Beam Clamp	3/4 through 4
BC 1/2	1/2	"	3/4 through 8
SDC-EG 2 1/2	1/2	Clevis Hanger	2 1/2
SDC-EG 3	1/2	"	3
SDC-EG 4	5/8	"	4
SDC-EG 5	5/8	"	5

SDC-EG 6	3/4		6
SDC-EG 8	3/4		8
			Metric only or English only or Primary/secondary

<i>Product Designation</i>	<i>Hanger Rod Size, mm</i>	<i>Component Description</i>	<i>For Nominal Pipe Size, in.</i>
00257366	3/8 (10)	Beam Clamp	3/4 through 4
00306600	3/8 (10)	Beam Clamp	3/4 through 4
00257367	1/2 (12)	Beam Clamp	5 through 8
00306601	1/2 (12)	Beam Clamp	5 through 8
00306602	3/8 (10)	Beam Clamp	3/4 through 4
00306603	1/2 (12)	Beam Clamp	5 through 8

Company Name:	Hilti Inc.
Company Address:	7250 Dallas Pkwy, Legacy Tower, Suite 1000, Plano, Texas 75024, USA
Company Website:	http://hilti.com
New/Updated Product Listing:	No
Listing Country:	United States of America
Certification Type:	FM Approved
Primary Class of Work:	1951-Pipe hangers For AS Sys